

TEST REPORT

CLIENT NAME : JONITE PRIVATE LIMITED

ADDRESS : 5 UPPER ALJUNIED LINK #01-01 QUARTZ INDUSTRIAL BUILDING
SINGAPORE 367903

ATTENTION TO : MR. DICKSON GOH

PHONE NO : 6383 3788

FAX NO : 6383 3718

ACCOUNT CHARGEABLE TO : JONITE PRIVATE LIMITED

PROJECT CODE : PT02061

PROJECT TITLE : GENERAL TESTING

SUBJECT & TEST METHOD : HEAVY METALS ANALYSIS

1. CADMIUM (Cd)	: EPA 3051A:2007 / EPA 6010D:2014
2. LEAD (Pb)	
3. MERCURY (Hg)	: EPA 3051A:2007 / ADM/ENV/004:2017
4. HEXAVALENT CHROMIUM	: EPA 3060A/7196A

JOB REF. : ADM/18/06066B

SAMPLE REF. : GRATING (STONE COMPOSITE)

DATE RECEIVED : 22-Oct-2018

DATE TESTED : 24-Oct-2018 TO 01-Nov-2018

DATE OF REPORT : 02-Nov-2018

TOTAL PAGES : 2 (including cover page)

Terms & conditions:

1. The Report is prepared based on the tests requested and on the specific items submitted to Admaterials for testing. Admaterials assumes no responsibility for variations in quality or other characteristics of items submitted under conditions over which Admaterials has no control. This Report does not constitute a recommendation for, or endorsement of, the item or material tested.
2. Admaterials agrees to use a reasonable degree of diligence in the manner of performing the tests, inspections or services but no warrants are given and none may be implied directly or indirectly relating to Admaterials' test results, services or facilities. In no event shall Admaterials be liable for collateral, special or consequential damage.
3. The Report must not be used in advertisements without the written consent of Admaterials.
4. The Report shall not be reproduced except in full and unless approval in writing has been given by Admaterials.
5. No other third party can obtain the Report through Admaterials, unless specified in the Admaterials registration form or he has received written instruction from the applicant to authorise Admaterials to do so.

ADMATERIALS TECHNOLOGIES PTE LTD

58 Sungei Kadut Loop Singapore 729501
Tel: +65 6362 9066 Fax: +65 6362 2080
Co. Reg. No.: 200805959C Email: admaterials.lab@exova.com
Website: www.exova.com, www.admaterials.com.sg



ADM/18/06066B

Page 2 of 2

TEST RESULT**Client's Name** : JONITE PRIVATE LIMITED**Sample Ref.** : GRATING (STONE COMPOSITE)

Test Items	Result	Unit	Test Method	SGBC Maximum Limits (ppm)	Met Criteria
Cadmium (Cd)	<0.50	ppm	EPA 3051A:2007 / EPA 6010D:2014	<100	Yes
Lead (Pb)	5.80	ppm		<1000	Yes
Mercury (Hg)	<0.10	ppm	EPA 3051A:2007 / ADM/ENV/004:2017	<1000	Yes
Hexavalent Chromium [Cr (VI)]	<10	ppm	EPA 3060A / 7196A	<1000	Yes

Remarks:

(1) < refers to 'less than'.

PREPARED BY:

TAY BOON HWA
Assistant Chemist
DID : (65) 6362 9019
Email : boonhwa.tay@Exova.com

APPROVED BY:

TAY CHIOU YANN
Manager (Environmental Laboratory)
DID : (65) 6362 9732
Email : Chiouyann.Tay@Exova.com